

## Title 24 Compliance – Constant Fan Operation

All,

**Title 24, Section 4, Mechanical Systems** requires constant *fan* operation in classrooms *when* those classrooms are occupied. Title 24, Subsection G, Mechanical Ventilation, Subchapter 121 (b) 2 and (d) states “Mechanical (*fans*) outdoor ventilation must be provided for all spaces (*when*) occupied that are not naturally ventilated.”

Please note that when fans are turned off when rooms are occupied the CO2 levels typically increase which can result in air quality concerns. Please report any fan operational concern to Maintenance and Operations Dispatch at 331-7193.